

County of Santa Cruz 037 - 25

Department Of Community Development and Infrastructure

701 OCEAN STREET, FOURTH FLOOR, SANTA CRUZ, CA 95060-4070 Public Works (831) 454-2160 Planning (831) 454-2580

https://cdi.santacruzcountyca.gov/

NOTICE OF EXEMPTION

To: Clerk of the Board

701 Ocean Street, Room 500 Santa Cruz, CA 95060

RECEIVED CLERK OF THE BOARD

MAR 19 2025

BOARD OF SUPERVISORS COUNTY OF SANTA CRUZ

Project Name: 2025 5th Ave Emergency Sewer Repair Project

Project Location: The project is located within the traffic circle at the intersection of 5th Avenue and East Cliff

Drive.

Assessor Parcel No.: County Road Right of Way

Project Applicant: Santa Cruz County Sanitation District

The proposed project involves replacement of up to 30 linear feet of existing deteriorated **Project Description:** public sewer lines located within the traffic circle at the intersection of 5th Avenue and East Cliff Drive. During routine camera inspection of the sewer pipe. Sanitation District Staff identified that the existing sewer line in this location has a large hole and requires immediate repair. The project will be completed through conventional open-cut trenching which includes saw cutting the existing road, digging a trench, removing the existing deteriorated 6" pipe, replacing it with new 8" pvc pipe, and reconstructing the paved roadway. The project may also require replacement of an existing manhole depending on field conditions observed at the time of construction. Construction will occur entirely within the existing paved roadway.

County of Santa Cruz **Agency Approving Project:**

Telephone No. 831-454-2814 **County Contact:** Ivan Messina

100

Date Completed: 3/6/2025

This is to advise that the County of Santa Cruz has found the project to be exempt from CEQA under the following criteria:

Exempt status: (check one) The proposed activity is not a project under CEQA Guidelines Section 15378. The proposed activity is not subject to CEQA as specified under CEQA Guidelines Section 15060 (c). The proposed activity is exempt from CEQA as specified under CEQA Guidelines Section 15061(b)(3). Ministerial Project involving only the use of fixed standards or objective measurements without personal judgment. Statutory Exemption other than a Ministerial Project (CEQA Guidelines Section 15260 to 15285). 15301(b)(d) Class 1. Existing Facilities

Reasons why the project is exempt:

The project involves repair of an existing public sewer system and involves no expansion of the existing use or capacity. None of the exceptions outlined in § 15300.2 apply.

Signature:	14	Date: 3/6/2025	Title: Resource Pla	STED AT THE CLEF
			OF THE DUALID OF SUPERV	ISONS OFFICE FOR

PERIOD COMMENCING 3 | 19 | 2025

AND ENDING 4 24 2025