

County of Santa Cruz 44-05292025-079

Department Of Community Development and Infrastructure

701 OCEAN STREET, FOURTH FLOOR, SANTA CRUZ, CA 95060-4070 Public Works (831) 454-2160 Planning (831) 454-2580

https://cdi.santacruzcountyca.gov/

NOTICE OF EXEMPTION

RECEIVED **CLERK OF THE BOARD**

MAY 29 2025

BOARD OF SUPERVISORS COUNTY OF SANTA CRUZ

To: Clerk of the Board

701 Ocean Street, Room 500 Santa Cruz, CA 95060

AA10-AA17 Vienna Drive Emergency Sewer Replacement Project **Project Name:**

County of Santa Cruz

Ivan Messina Telephone No. 831-454-2814

The project is located on Vienna Drive between Jennifer Drive and Cheryl Way **Project Location:**

Assessor Parcel No.: County Road Right of Way

Santa Cruz County Sanitation District **Project Applicant:**

The proposed project involves replacement of approximately 600 linear feet of existing 8" **Project Description:** asbestos-cement pipe. The pipe is broken and in immediate need of repair to protect public health and safety. The project will be completed through conventional open-cut trenching which includes saw cutting the existing road, digging a trench, removing the existing broken pipe, replacing it with new 8" pvc pipe, and reconstructing the paved roadway. Construction will occur entirely within the existing paved roadway.

Date Completed: 5/28/2025 This is to advise that the County of Santa Cruz has found the project to be exempt from CEQA under the following criteria: Exempt status: (check one) The proposed activity is not a project under CEQA Guidelines Section 15378.

The proposed activity is not subject to CEQA as specified under CEQA Guidelines Section 15060 (c). The proposed activity is exempt from CEQA as specified under CEQA Guidelines Section 15061(b)(3).

Ministerial Project involving only the use of fixed standards or objective measurements without personal judgment.

Statutory Exemption other than a Ministerial Project (CEQA Guidelines Section 15260 to 15285). 15269(b); 15282(k)

□ Categorical Exemption

Agency Approving Project:

County Contact:

15301(b)(d) Class 1. Existing Facilities

Reasons why the project is exempt:

The project involves repair of an existing public sewer pipe which is broken and in immediate need of repair to protect public health and safety and involves no expansion of the existing use or capacity. The pipeline is within the existing County road right of way and none of the exceptions outlined in § 15300.2 apply.

Signature:	Date: 5/28/2025	Title:	Resource Planner IV

112

THIS NOTICE HAS BEEN POSTED AT THE CLERK OF THE BOARD OF SUPERVISORS OFFICE FOR A

PERIOD COMMENCING _______

AND ENDING